Sectt. II-27—10,002—6-9-28.

Law (Genl.) (1929) Department.

Misc. SERIES.

G.O. No. 447

DATED 28-1-1929

[Despatch Abstract.]

Petroleum

Special licenses - storage at Mangalore - Burmah - Shell Oil Storage and Distributing Company of India, Limited - granted.

Form G. 11.

ALL COMMUNICATIONS TO BE ADDRESSED TO THE COMPANY

(f 53) C
21-1-29

BURMAH-SHELL

SA/MG. OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.

(INCORPORATED IN ENGLAND)

TELEGRAMS:—"BURMAHSHEL"
TELEPHONE No. 3964 (4 LINES)

POST BOX 157,
MADRAS.

IN REPLY PLEASE REFER TO No. G/2436

ASSISTANT SECY TO GOVT 19 JAN 1929

18th January 1929

The Secretary to Government,
Law Department,
Fort St. George,
M A D R A S.

GENERAL DEPT.

ESTABLISHMENT.

Sir,

Petroleum Special Licenses -Mangalore.

We have the honour to inform you that on the 14th ultimo, we applied to the District Magistrate of South Kanara, for the renewal and transfer of the enclosed Special Licenses to our name which he has returned to us without complying,on the ground that he cannot transfer them in view of your Memo No. 6344-C3 Law (General) dated 21st December 1928, and he has asked us to apply to you direct. We are therefore submitting them to you and request that you will be kind enough to cancel these and to issue fresh ones, for the same places as described in the old licenses, in the name of our Company viz. Burmah-Shell Oil Storage & Distributing Co. of India Ltd,. The prescribed license fees have been remitted as per enclosed Chalan No. 52.

As desired by the District Magistrate, we also return the Special Licenses Nos. 5 & 6 of 29 dated 5/12/28, transferred and renewed for the current year, for cancellation and request that fresh licenses may be granted in our name.

In this connection we would request you to kindly advise the District Magistrate, South Kanara, to issue a refund warrant

Form G. 11.

BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.
(INCORPORATED IN ENGLAND)
MADRAS.

for the sum of Rs. 4/- sent to him as transfer fees for the enclosed 4 licenses.

We have the honour to be,
Sir,
Your obedient Servants,
For BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.,

V. Morley.

Enclos. 11 Sheets.



£6/I 3

BURMAH-SHELL
MADRAS
17 JANUARY 1929
ANSWERED

No. 52

DUPLICATE

Chalan for payment of money into the Imperial Bank of Madras at Madras

By whom paid.	On what account.	Amount. Rs.	A.	P.	Reference to Revenue Register.
Messrs Burmah Shell Oil Storage and distributing Company of India Limited Madras	Transfer fees of 2 petroleum licences 2-0-0 Fees for the renewal of 2 licences 16-0-0				XVII Administration of Justice Misc. Fees and Fines Fees for petroleum licences
	Total (in words and figures).	18			

Rupees eighteen only

Imperial Bank of Madras at

The 192 . Entered—Correct.

M. Ekambaram Mudaliar
Signature of Remitter.

Initials of Treasury Accountant.

Bank Accountant.

RECEIVED RUPEES

IMPERIAL BANK OF INDIA
13 JAN 1929
MADRAS

Signature of Cashier.

Signature of Agent.

Dated 192 .

JAN 29

4

(P)

1927

1647

Special License to possess dangerous petroleum in one receptacle containing more than sixty-five gallons.

(Rule 6 Chapter IV of Part II of the Petroleum Rules)

No.

Fee Rs.40/-

License is hereby granted to The Tank Storage Company (India) Limited, Madras

for the storage in the licensed premises described below ~~nil~~ 10,000 of/ gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in Notification No. 441, dated 24th July 1909 and to the further conditions on the back of the license.

Secretary to the Government of Madras.

Dated the 15th June 1927.

(Description of the licensed premises above referred to).

In the Company's ~~petrol shed~~ depot at Mangalore.

5

6. The petroleum shall enter the tank 'under seal' and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze 32 mesh and fitted with a hood or the open end shall be fitted with a inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing to execute any repairs to the storage premises, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank before being repaired, shall be cleared

"8(a) When a tank in position is open for cleaning or repair, no lamps of any description either ordinary or electric, electric torches electric cables or electric fans shall be brought near the manhole of the tank. The inside of the tank may be lighted by the use of mirrors".

10. All due precautions shall be taken for the prevention of unauthorized persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage of premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act.

13. Except when absolutely necessary for the purpose of condition 8 petroleum shall on no account be pumped into any receptable other than that clamped or fitted to a motor ~~xxxx~~ vehicle.

~~--~~. On no account shall tins or drums be filled with dangerous petroleum from the pump or pumps.

Fees Rs 40/-

Special License renewed for the year ending

31.12.1928.

27.11.1927

District Magistrate

26.11.27

No. 1929 Fees paid Rupees one for Transfer and forty for Renewal -Total Rs. 41

Transferred to the name of the Burmah Shell-Oil Storage and Distributing Company of India Limited and RENEWED for the year ending 31-12-1928//

DISTRICT MAGISTRATE SOUTH CANARA

7.12.28.

District Magistrate of South Kanara

7/28

G.O. 1502 - 1567

Special License to possess dangerous petroleum in one receptacle containing more than sixty-five gallons.

(Rule 6 Chapter IV of Part II of the Petroleum Rules)

No.

Fee Rs. 40/-

License is hereby granted to The Tank Storage Company (India) Limited, Madras

for the storage in the licensed premises described below of 10,000 / gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in Notification No. 441, dated 24th July 1909 and to the further conditions on the back of the license.

Raghavaiah
Secretary to the Government of Madras.

Dated the 15th June 1927.

(Description of the licensed premises above referred to).

In the Company's ~~petrol shed~~ Depot at Mangalore.

8

6. The petroleum shall enter the tank 'under seal' and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze 32 mesh and fitted with a hood or the open end shall be fitted with a inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing to execute any repairs to the storage premises, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising

"8(a) When a tank in position is open for cleaning or repair, no lamps of any description either ordinary or electric, electric torches electric cables or electric fans shall be brought near the manhole of the tank. The inside of the tank may be lighted by the use of mirrors".

tion of unauthorized persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage of premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. Except when absolutely necessary for the purpose of condition 8 petroleum shall on no account be pumped into any receptable other than that clamped or fitted to a motor ~~mmk~~ vehicle.

Fees Rs 40/-

Special Licence renewed for the year ending

31. 12. 1928

27. 11. 1927 } District Magistrate

26.11.27

Fees paid Transfer Re. 1 and Renewal Rs. 40

No 5 - Transferred to the name of the Burmah-Shell-Oil Storage
1929 and Distributing Co., of India Limited and
RENEWED for the year ending 31-12.-1929.

DISTRICT MAGISTRATE SOUTH CANARA

District Magistrate of South Kanara

" " 5.12.1928

DUPLICATE COPY

(G.O.No. 1949 Law (General), dated 21st June 1927.

***

Special License to possess dangerous petroleum in one receptacle containing more than sixty five gallons.

(Rule 6 Chapter IV of Part II of the Petroleum Rules)

No.

Fee Rs. 8/-

License is hereby granted to **the Agent of the Burma Oil Company Limited at Mangalore, for the** storage in the licensed premises described below of **500/-** gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in Notification No.441, dated 24th July 1909 and to the further conditions on the back of the license.

Dated the **21st June 1927.**

T. RAGHAVAYYA,
Secretary to the Government
of Madras.

(Description of the licensed premises above referred to)

The licensed premises are situated at Hampankatta in the town of Mangalore and consists of a gas tight tank of a capacity of 500 gallons sunk underground.

(True copy)

Dated, Fort St.George,
the 9th October 1928.

Acting Secretary to Government.
LAW DEPARTMENT.

BURMAH-SHELL
MADRAS
17 JANUARY 1929
ANSWERED

11 5

CONDITIONS OF LICENSE.

1. The Petroleum shall be stored in one gas tight metal tank of a capacity of 500 gallons sunk completely under ground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand earth or clay so that no air space is left below ground level and the tank is not visible.

2. A pump or pumps shall be placed in the position shown on plan submitted. The pipe connection between the tank and the pump or pumps shall be placed underground and all joints valves and cocks shall be gas tight.

3. For the purpose of charging the tanks of locomotives the petroleum shall be:-

(a) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self closing cock and nozzle, into the tanks of locomotives, or

(b) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self closing cock and nozzle into the tanks of locomotives, or

(c) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

4. All tanks, pumps, pipes and fittings shall be strongly constructed of best materials.

5. All service or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.

6. The petroleum shall enter the tank 'under seal' and all tanks shall be fitted with a vent pipe leading to the open air, the open end being covered with brass gauze 32 mesh and fitted with a hood or the open end shall be fitted with an

an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premeses, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same.

8(a). When a tank in position to open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors.)

9. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 ~~of~~ or section 6 of the Act.

10. All due precautions shall be taken for the prevntion of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage of premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary and shall prevent any other person from doing such act.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. Except when absolutely necessary for the purpose of condition 8, Petroleum, shall on no account, be pumped into any receptacle other than that clamped or fitted to a motor vehicle.

Special License to possess dangerous petroleum in one receptacle containing more than sixty five gallons.

(Rule 6 Chapter IV of Part II of the Petroleum Rules)

No.

Fee Rs. 8/-

License is hereby granted to the Agents of the Asiatic Petroleum Company (India) Limited at Mangalore for the storage in the licensed premises described below of 500 gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in Notification No.441, dated 24th July 1909 and to the further conditions on the back of the license.

Dated the 30th July 1927.

Secretary to the Government of Madras.

(Description of the licensed premises above referred to)

The licensed premises are situated at Hampankatta in the town of Mangalore and consist of a gas tight tank of a capacity of 500 gallons sunk under-ground.

ASST SECY TO GOVT. M.D. 3 AUG 1928 LAW DEPT.

Fee Rs 8

Renewed for the year ending 31.12.1928.

5.12.1927 District Magistrate

5.12.27

CONDITIONS OF LICENSE. 14

1. The petroleum shall be stored in one gas tight metal tank of a capacity of 500/- gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay so that no air space is left below ground level and the tank is not visible.

2. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas tight.

3. For the purpose of charging the tanks of locomotives the petroleum shall be

(a) Pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self closing cock and nozzle, into the tanks of locomotives, or

(b) Pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self closing cock and nozzle, into the tanks of locomotives, or

(c) Pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

4. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

5. All services or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.

6. The petroleum shall enter the tank 'under seal' and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze 32 mesh and fitted with a hood or the open end shall be fitted with a inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing to execute any repairs to the storage premises,

premises, which may, in the opinion of such officer be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same.

8(a) When a tank in position is open for cleaning or repair no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

10. All due precautions shall be taken for the prevention of a unauthorized persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage of premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. Except when absolutely necessary for the purposes of condition 8, petroleum shall, on no account, be pumped into any receptacle other than that clamped or fitted to a Motor Vehicle.

(Law (General) Dept

[C no. 537 C] From the Burmah Shell Oil Storage and Distributing Company of India Limited no. S. 2436 of 18.1.29.

Subject: Transfer of Special licenses

The firm has paid Rupees four as fees for the transfer of the special licenses. As special licenses granted under rule 6, Chapter IV. Part II of the Petroleum Rules cannot be transferred, no fees need be levied for the issue of fresh licenses. The fees paid by the firm may be refunded

2. A draft order is submitted.

Smd.
25.1.29

PSR
26.1.29

L.S 27.

Low
27-1

Scott. 11-5 (a)—48,004—6-11-28. (6)

60/28.1

law (general) DEPARTMENT

	Date.	Initials.
When received for Fair-copying.		
When copied ..	28/1	
When examined ..		
When signed ..		
When despatched ..		

Petroleum

Special licenses - Storage at Mangalore - Burmah - Shell oil Storage and Distributing Company of India, Ltd granted.

READ AGAIN G.O. No. ....., dated 192

" " " " ..... " 192

READ ALSO:—

C. No. 537 From the Burmah-Shell oil Storage & Distributing Co. of India Ltd, No. S. 2436 dated 18-1-1929

" " ..... " " ..... " 192

" " ..... " " ..... " 192

ORDER.

No. 164, dated 1/2/ 192/.

This —

Two special licenses under rule 6, chapter IV of Part II of the Petroleum Rules, for the Storage in bulk of 10000 (ten thousand) gallons of dangerous petroleum each of the two under ground tanks in the company's petrol depot at Mangalore and two Special licenses under rule 6, chapter IV of Part II of the Petroleum Rules, for the Storage of 500 (five hundred) gallons of dangerous petroleum in each of the company's underground tanks at Hampankatta in the town of Mangalore.

are granted to the Burmah Shell Oil Storage and Distributing Company of India, Limited

2. The District Magistrate, South Kanara, is requested to refund to the Company the sum of Rupees four (4/-) being the sum paid by the firm ~~towards~~ as fees for the transfer of the four licenses.

3. ~~The licenses with the~~ ~~forwarded to the District Magistrate, South Kanara for delivery~~

To

The Burmah-Shell Oil Storage and Distributing Co: of India Limited with licenses

The D. M. South Kanara (a+o)

The Chief Inspector of Explosives (q+o) with copy of licenses

The Accountant General Madras

Smf. 5.1.29

pgg 26.1.29

dt 26-1-29

JM 29/1

Rule 1, chapter IV, Part II:- Save as provided in rules 9 (1), 13 and 14 of this chapter, every license for the possession of petroleum shall remain in force until the 31st December next following the date of issue of the license.

SPECIAL LICENSE TO POSSESS DANGEROUS PETROLEUM IN ONE RECEPTACLE or more than one receptacle forming one Unit and CONTAINING MORE THAN SIXTY-FIVE GALLONS.

(RULE 6, CHAPTER IV of PART II.)

No. Fee Rs. 40

License is hereby granted to [illegible] for the storage in the licensed premises described below of [illegible] gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in notification No. [illegible], dated [illegible] and to the further conditions attached hereto

[illegible]

The [illegible] 19[illegible]. Secretary to the Government of [illegible]

(Description of the licensed premises above referred to.)

The licensed premises are situated [illegible] and consist of a gas-tight tank of a capacity of [illegible] gallons sunk underground.

[illegible]

Conditions of license.

1. The petroleum shall be stored in one gas-tight metal tank of a capacity of 10,000 gallons sunk completely underground in the position shown on plan submitted, and placed in a pit, the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

2. A pump or pumps shall be placed in the position shown on plan submitted and all joints, valves and cocks shall be gas-tight.

All tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

3. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

5. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

6. The tank, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

7. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

8. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

9. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted except in those places set apart for the purpose and approved by the Chief Inspector of Explosives in India.

10. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

*****

Rule 1, chapter IV, Part II:- Save as provided in rules 9 (1), 13 and 14 of this chapter, every license for the possession of petroleum shall remain in force until the 31st December next following the date of issue of the license.

SPECIAL LICENSE TO POSSESS DANGEROUS PETROLEUM IN ONE RECEPTACLE or more than one receptacle forming one unit and CONTAINING MORE THAN SIXTY-FIVE GALLONS.

(RULE 6, CHAPTER IV of PART II.)

No. Fee Rs. 40/- Rupees Forty only

License is hereby granted to M/s Burmah-Shell Oil Storage and Distributing Company of India, Limited for the storage (on account)

in the licensed premises described below of 10,000 gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in notification No. 441, dated the 24th July 1909 and to the further conditions attached hereto.

Sd/- [illegible]

The January 19-7. Secretary to the Government of Madras, Law Department

(Description of the licensed premises above referred to.)

The licensed premises are situated for the company's depot at Mangalore and consist of a gas-tight tank of a capacity of 10,000 gallons sunk underground.

[illegible]

[illegible]

Conditions of license.

1. The petroleum shall be stored in one gas-tight metal tank of a capacity of 10,000 gallons sunk completely underground in the position shown on plan submitted, and placed in a pit. the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

2. A pump or pumps shall be placed in the position shown on plan submitted and all joints, valves and cocks shall be gas-tight.

3. All tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

4. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

5. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

6. The tank, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

7. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

8. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

9. Every person maraging or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted except in those places set apart for the purpose and approved by the Chief Inspector of Explosives in India.

10. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

*****

Rule 1, chapter IV, Part II:- Save as provided in rules 9 (1), 13 and 14 of this chapter, every license for the possession of petroleum shall remain in force until the 31st December next following the date of issue of the license.

SPECIAL LICENSE TO POSSESS DANGEROUS PETROLEUM IN ONE RECEPTACLE or more than one receptacle forming one unit and CONTAINING MORE THAN SIXTY-FIVE GALLONS.

(RULE 6, CHAPTER IV of PART II.)

No. Fee Rs. 8/-
(Rupees Eight only)

License is hereby granted to the Burmah Shell Oil Storage and Distributing Company of India, Limited for the storage in the licensed premises described below of one hundred gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in notification No. 441, dated 24th July 1909 and to the further conditions attached hereto.

S/C 1876-Y

The January 19 24. Secretary to the Government of Burma, Civil Department

(Description of the licensed premises above referred to.)

The licensed premises are situated at Kemendine Hill in the Town of Rangoon and consist of a gas-tight tank of a capacity of one gallons sunk underground.

P.S.O. 1/4

8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 8 or when the tank and pump are erected completely inside a Dangerous Petroleum Installation, petroleum shall, on no account, be filled from the tank or pump or from a barrel of oil supplied by Petroleum Companies to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum shall be stored in one gas-tight metal tank of a capacity of 500 gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be--

(a) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(b) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing

self-closing cock and nozzle, into the tanks of locomotives, or

(c) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

6. All service or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.

7. The petroleum shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

8. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

9. The tank, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

10. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

11. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

11 12. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a Kerbside pump.

12 13. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13 14. This license shall be held to cover the use of a portable Kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use.

T.P.S/16.9.27.

Rule 1, chapter IV, Part II:- [redacted] provided in rules 9 (1), 13 and 14 of this chapter, every license for the possession of petroleum shall remain in force until the 31st December next following the date of issue of the license.

SPECIAL LICENSE TO POSSESS DANGEROUS PETROLEUM IN ONE RECEPTACLE or more than one such receptacle forming one unit and CONTAINING MORE THAN SIXTY-FIVE GALLONS.

(RULE 6, CHAPTER IV of PART II.)

No.

Fee Rs. 8/-
(Rupees Eight only)

License is hereby granted to the Burmah-Shell Oil Storage and Distributing Company of India, Limited

for the storage in the licensed premises described below of 500 (Five hundred) gallons of dangerous petroleum in one tank subject to the rules for the storage of petroleum published in notification No. 441, dated 24th July 1909, and to the further conditions attached hereto.

The 9th January 1924. Secretary to the Government of Madras, Law Department

(Description of the licensed premises above referred to.)

The licensed premises are situated at Kampanakalli in the town of Mangalore and consist of a gas-tight tank of a capacity of 500 gallons sunk underground.

P821
26.9

8 or for testing the accuracy of a pump's discharge by means of a standard measure

CONDITIONS OF LICENSE.

1. Except when absolutely necessary for the purposes of condition 2 or when the tank and pump are erected completely inside a Dangerous Petroleum Installation, petroleum shall, on no account, be filled from the tank or pump or from a barrel of oil supplied by Petroleum Companies to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum shall be stored in one gas-tight metal tank of a capacity of 500 gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of locomotives the petroleum shall be--

(a) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(b) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing

self-closing cock and nozzle, into the tanks of locomotives, or

(c) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

6. All service or measuring tanks shall be fitted with overflow and emptying pipes returning to the storage tank.

7. The petroleum shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

8. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

9. The tank, before being repaired, shall be cleared of all dangerous petroleum and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

10. The license holder is prohibited from delivering any quantity of dangerous petroleum exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

11. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum kept and to the vessels containing or having actually contained the same.

12. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a Kerbside pump.

13. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

14. This license shall be held to cover the use of a portable Kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use.

T.P.S/16.9.27.